

ADDENDUM No. 1

November 20, 2017

PROJECT: WEST GATE ENTRANCE EXTERIOR IMPROVEMENTS-FENCING PACKAGE
BEXAR COUNTY ARENAS

ARCHITECT: H. Saldana & Associates, Inc.
723 S. Flores St.
San Antonio, Texas 78204

This Addendum modifies the Contract Documents dated October 6, 2017. Work not specifically deleted, modified, changed or altered by this Addendum shall remain in effect as originally issued.

QUESTIONS RECEIVED FROM POTENTIAL BIDDERS:

AD1.1 Question 1: "The gate spec calls for Ameristar Transport gate. So, can we propose an Ameristar Fence panel that is similar to the design on the drawing or are you looking for the custom made panel from the details?"

Response: All bids are to be based solely on what is shown on the Drawings and in the Specifications for this Project.

Question 2: "Some of the details call for aluminum fence panels and some refer to steel. Are the panels to be aluminum or steel?"

Response: All fence panels are to consist of steel members; and all gate panels are to be made of aluminum components to minimize the weight of panels.

SPECIFICATION MODIFICATIONS: None

DRAWING MODIFICATIONS:


AD1.2 Drawing Sheet A-1.0: At "Existing Conditions/Demolition Site Plan", change dimension of "277'-7" (Field Verify)" to "337'-11"(Field Verify)".

- AD1.3 Drawing Sheet A-1.1: Add note to Details "2" and "5" to read:
"See Detail 'S-103' for anchoring fence posts to concrete flatwork."
- AD1.4 Drawing Sheet S-1: Add Detail "S-103" as per Attachment "AD1.A".

END OF ADDENDUM No. 1




NOTE:
SEE ARCHITECTURAL
PLAN FOR FENCE
POST LOCATIONS.



METAL FENCE POST
BASE PLATE DETAIL AT EXISTING
CONCRETE FLATWORK S-103


"ATTACHMENT AD1.A"



THE SEAL APPEARING ON
THIS DOCUMENT WAS AUTHORIZED
BY ROBERT E. MARTINEZ, P.E. # 89387

WEST GATE
BEXAR COUNTY ARENAS
FENCING PACKAGE

3201 E. HOUSTON ST.
SAN ANTONIO, TX 78219



6800 Park Ten Blvd. Suite 234E
SAN ANTONIO, TX 78213
(210) 320-1144 (210) 320-2251 (fax)
robert_rengineeringcorp.com
T.B.P.E. FIRM NO. 6444

DATE:
11-20-17
JOB NO:
17-130

SHEET NO:
S-103